



GLA WATER CONSULTANTS, INC.

Water Treatment Chemicals & Equipment

Mailing: 201 Burch Drive • Moon Township, PA 15108 • Phone: (412) 262-4827

Shipping: 1200 Fourth Avenue • Coraopolis, PA 15108 • Fax: (412) 375-7645

October 1, 2018

Mr. Craig Zeigler
Burgettstown School District
100 Bavington Road
Burgettstown, PA 15021

Subject: Burgettstown School District Total Coliform Analyses

Craig,

Enclosed is a copy of the microbiological testing results for total coliform related to the samples collected on September 24, 2018.

All testing revealed the absence of coliform; thus the water would be considered safe per DEP guidelines on the day of the testing.

If you have any questions about this report, feel free to call me at 412-262-4827.

Respectfully submitted,

Jay Farmerie

JJF:mrf

Member Company



GLA WATER CONSULTANTS, INC.

WATER TREATMENT CHEMICALS & EQUIPMENT

Lab Services Division

Client:

Burgettstown School District
100 Bavington Road
Burgettstown, PA 15021

Date Sampled: 09/24/18
Date Received: 09/24/18
Date Analyzed: 09/27/18

SPECIAL TEST PROCEDURES

SAMPLE: High School Kitchen Time: 09:40

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: High School 1st Floor Hall Water Fountain Time: 09:45

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: High School Room 131 Faculty Sink Hot Time: 09:49

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: Middle School Room 112 Faculty Lounge Time: 09:56

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: Middle School Water Fountain by Room 04 Time: 10:00

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines

Member Company



GLA WATER CONSULTANTS, INC.

WATER TREATMENT CHEMICALS & EQUIPMENT

Lab Services Division

Client:

Burgettstown School District
100 Bavington Road
Burgettstown, PA 15021

Date Sampled: 09/24/18
Date Received: 09/24/18
Date Analyzed: 09/27/18

SPECIAL TEST PROCEDURES

SAMPLE: Middle School Water Fountain by Room 204 Time: 10:04

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: High School Water Fountain by Room 225 Time: 10:06

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: Administration – Kitchen Hot Time: 10:23

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: Elementary 1st Floor Head Start Time: 10:26

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: Elementary – Kitchen Hot Time: 10:29

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

Member Company



GLA WATER CONSULTANTS, INC.

WATER TREATMENT CHEMICALS & EQUIPMENT

Lab Services Division

Client:

Burgettstown School District
100 Bavington Road
Burgettstown, PA 15021

Date Sampled: 09/24/18
Date Received: 09/24/18
Date Analyzed: 09/27/18

SPECIAL TEST PROCEDURES

SAMPLE: Elementary – 2nd Floor Boys’ Bathroom Time: 10:33

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: Elementary 2nd Floor Water Fountain by Restroom Time: 10:35

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: Elementary Room 128 Hot Time: 10:37

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: Elementary – 1st Floor Restroom Time: 10:39

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

SAMPLE: Elementary – 1st Floor Water Fountain by Restroom Time: 10:42

Total Coliform (SM9223 B) Absent / 100 ml
This water does meet EPA / PA DEP Guidelines.

Member Company

